



2019 Annual Drinking Water Quality Report ***Lincoln County Water System***

PWS ID# 01-55-035

The Lincoln County Department of Public Works is pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to provide you with this information, because informed customers are our best allies. **If you have any questions about this report or concerning your water, please contact Adam Jolicoeur, Water Treatment Plant Superintendent at 704-483-7070.**

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

What the EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk for infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lincoln County Department of Public Works is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components in houses and businesses. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

When You Turn on Your Tap, Consider the Source

The water that is treated by this system is from Lake Norman. Additional water is purchased from the City of Lincolnton. Information regarding City of Lincolnton's water quality is available on our website.

Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environment and Natural Resources (DENR), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for Lincoln County was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

Susceptibility of Sources to Potential Contaminant Sources (PCSs)

Source Name	Susceptibility Rating	SWAP Report Date
Lake Norman	Higher	September 1, 2017

The complete SWAP Assessment report for Lincoln County may be viewed on the Web at:

https://www.ncwater.org/files/swap/SWAP_Reports/0155035_9_1_2017_17_22.pdf

Note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to swap@ncdenr.gov. Please indicate your system name (Lincoln County), PWSID (01-55-035), and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-707-9098.

It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the systems’ potential to become contaminated by PCS’s in the assessment area.

Help Protect Your Source Water

Protection of drinking water is everyone’s responsibility. You can help protect your community’s drinking water source(s) in several ways: (examples: dispose of chemicals properly; take used motor oil to a recycling center, proper sedimentation and erosion control, volunteer in your community to participate in group efforts to protect your source, etc.).

Water Quality Data Table of Detected Contaminants

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The table below lists all the drinking water contaminants that we detected in the last round of sampling for each particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2019.** The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

****Unregulated Contaminants:**

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

Important Drinking Water Definitions:

Not-Applicable (N/A) – Information not applicable/not required for that particular water system or for that particular rule.

Non-Detects (ND) - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.

Parts per million (ppm) or Milligrams per liter (mg/L) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Million Fibers per Liter (MFL) - Million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Residual Disinfection Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfection Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Locational Running Annual Average (LRAA) – The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.

Total Organic Carbon (TOC) - has no health effects, however, organics provide a medium for the formation of disinfection byproducts. The TOC compliance criterion applies only to treated water.

Cysts/L – The number of cysts per a liter of water.

Extra Note: MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Asbestos Contaminant

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Total Asbestos (MFL)	4/17/12	N	N/D			7	7	Decay of asbestos cement water mains; erosion of natural deposits

REVISED TOTAL COLIFORM RULE:**Microbiological Contaminants in the Distribution System**

Contaminant (units)	MCL Violation Y/N	Your Water	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (presence or absence)	N	1	0	TT*	Naturally present in the environment
<i>E. coli</i> (presence or absence)	N	0	0	<p>Routine and repeat samples are total coliform-positive and either is <i>E. coli</i>-positive or system fails to take repeat samples following <i>E. coli</i>-positive routine sample or system fails to analyze total coliform-positive repeat sample for <i>E. coli</i></p> <p><u>Note:</u> If either an original routine sample and/or its repeat samples(s) are <i>E. coli</i> positive, a Tier 1 violation exists.</p>	Human and animal fecal waste

* If a system collecting 40 or more samples per month finds greater than 5% of monthly samples are positive in one month, an assessment is required.

E.coli - Fecal coliforms and E.coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely-compromised immune systems.

Fecal Indicators (enterococci or coliphage) - Fecal indicators are microbes whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term health effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

Turbidity*

Contaminant (units)	Treatment Technique (TT) Violation Y/N	Your Water	Treatment Technique (TT) Violation if:	Likely Source of Contamination
Turbidity (NTU) - Highest single turbidity measurement	N	0.08 NTU	Turbidity > 1 NTU	Soil runoff
Turbidity (NTU) - Lowest monthly percentage (%) of samples meeting turbidity limits	N	100% In Compliance	Less than 95% of monthly turbidity measurements are \leq 0.3 NTU	

* Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The turbidity rule requires that 95% or more of the monthly samples must be less than or equal to 0.3 NTU.

Nitrate/Nitrite Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Nitrate (as Nitrogen) (ppm)	2/4/19	N	N/D	N/A		10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (as Nitrogen) (ppm)	2/4/19	N	N/D	N/A		1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Nitrate: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

Lead and Copper Contaminants

Contaminant (units)	Sample Date	Your Water	# of sites found above the AL	MCLG	MCL	Likely Source of Contamination
Copper (ppm) (90 th percentile)	07/2018	.10	0	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (ppb) (90 th percentile)	07/2018	N/D	0	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Total Organic Carbon (TOC)

Contaminant (units)	TT Violation Y/N	Your Water (RAA) Removal	Range Monthly Ratio Low - High	MCLG	TT	Likely Source of Contamination	Compliance Method ACC#2)
Total Organic Carbon (removal ratio) (TOC)-TREATED	N	1.17	0 -1.6	N/A	TT	Naturally present in the environment	ACC# 2

Alternative Compliance Criteria (ACC) ACC # 2 Treated Water TOC < 2.0 mg/L

Disinfectant Residuals Summary

	Year Sampled	MRDL Violation Y/N	Your Water (highest RAA)	Range		MRDLG	MRDL	Likely Source
				Low	High			
Chlorine (ppm)	2019	N	1.17	0.33	1.85	4	4.0	An additive that is used to control microbes in water

Stage 2 Disinfection Byproduct Compliance - Based upon Locational Running Annual Average (LRAA)

Disinfection Byproduct	Year Sampled	MCL Violation Y/N	Your Water (highest LRAA)	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
TTHM (ppb)						N/A	80	Byproduct of drinking water disinfection
B01	2019	N	64	28 - 112				
B02	2019	N	60	20 - 81				
B03	2019	N	58	26 - 88				
B04	2019	N	54	23 - 67				

HAA5 (ppb)						N/A	60	Byproduct of drinking water disinfection
B01	2019	N	47	21 - 45				
B02	2019	N	42	25 - 45				
B03	2019	N	45	23 - 45				
B04	2019	N	42	20 - 46				

For TTHM: *Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.*

For HAA5: *Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.*

Radioactive Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	MCLG	MCL	Likely Source of Contamination
Alpha emitters (pCi/L)	3/13/18	N	N/D	0	15	Erosion of natural deposits
Beta/photon emitters (pCi/L)	3/13/18	N	N/D	0	50 *	Decay of natural and man-made deposits
Combined radium (pCi/L)	3/13/18	N	N/D	0	5	Erosion of natural deposits
Uranium (pCi/L)	3/13/18	N	N/D	0	20.1	Erosion of natural deposits

* Note: The MCL for beta/photon emitters is 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for beta particles. articles.

(UCMR 4) Unregulated Contaminant Monitoring Rule 4 Assessment Monitoring

Contaminants and Analytical Results

Unregulated (Clearwell Effluent Samples)

Contaminant (units)	Sample Date	Your Water	
---------------------	-------------	------------	--

Manganese (ppb)	5/18	1.4	
Manganese (ppb)	8/18	0.53	
Manganese (ppb)	11/18	2.8	
Manganese (ppb)	2/19	.64	

Unregulated (Raw Water Source Samples)

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
Bromide (mg/L)	5/18 8/18 11/18	0.023	0.02 - 0.03	
Total Organic Carbon (ppb)	5/18 8/18 11/18	1834	1582 - 2140	
Total Organic Carbon (ppb)	3/19	1513	1513	

Unregulated (Distribution System Samples)

Bethel Pump Station (Interconnection with the City of Lincoln)

Contaminant (units)	Sample Date	Your Water	
Manganese (ppb)	8/18	1.0	
Manganese (ppb)	11/18	0.49	
Manganese (ppb)	2/19	0.40	

(B01) Union Elementary

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
Monochloroacetic Acid (ppb)	5/18 8/18 11/18	3.6	ND – 4.8	
Monobromoacetic Acid (ppb)	5/18 8/18 11/18	.10	ND - .30	
Dichloroacetic Acid (ppb)	5/18 8/18 11/18	21.7	21 - 22	
Trichloroacetic Acid (ppb)	5/18 8/18 11/18	22.7	22 - 23	
Bromochloroacetic Acid (ppb)	5/18 8/18 11/18	4.7	3.2 – 6.1	
Dibromoacetic Acid (ppb)	5/18 8/18 11/18	.36	ND - .57	
Bromodichloroacetic Acid (ppb)	5/18 8/18 11/18	4.17	2.8 – 5.1	
Chlorodibromoacetic Acid (ppb)	5/18 8/18 11/18	.34	ND - .54	
Tribromoacetic Acid (ppb)	5/18 8/18 11/18	ND	N/A	
Total Haloacetic Acids (ppb)	5/18 8/18 11/18	47	45 - 50	

Total Haloacetic Acids UCMR4 (ppb)	5/18 8/18 11/18	56	52 - 60
Total Haloacetic Acids – Br (ppb)	5/18 8/18 11/18	9.4	6.3 - 12

(B01) Union Elementary

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
Monochloroacetic Acid (ppb)	2/19	ND	N/A	
Monobromoacetic Acid (ppb)	2/19	ND	N/A	
Dichloroacetic Acid (ppb)	2/19	14	14	
Trichloroacetic Acid (ppb)	2/19	17	17	
Bromochloroacetic Acid (ppb)	2/19	2.3	2.3	
Dibromoacetic Acid (ppb)	2/19	ND	N/A	
Bromodichloroacetic Acid (ppb)	2/19	2.1	2.1	
Chlorodibromoacetic Acid (ppb)	2/19	ND	N/A	
Tribromoacetic Acid (ppb)	2/19	ND	N/A	
Total Haloacetic Acids (ppb)	2/19	31	31	
Total Haloacetic Acids UCMR4 (ppb)	2/19	35	35	
Total Haloacetic Acids – Br (ppb)	2/19	4.3	4.3	

(B02) North 321 Fire Dept.

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
Monochloroacetic Acid (ppb)	5/18 8/18 11/18	2.67	ND – 5.1	
Monobromoacetic Acid (ppb)	5/18 8/18 11/18	ND	N/A	
Dichloroacetic Acid (ppb)	5/18 8/18 11/18	21.3	18 - 24	
Trichloroacetic Acid (ppb)	5/18 8/18 11/18	19.7	16 - 23	
Bromochloroacetic Acid (ppb)	5/18 8/18 11/18	3.5	2.6 – 4.4	
Dibromoacetic Acid (ppb)	5/18 8/18 11/18	ND	N/A	
Bromodichloroacetic Acid (ppb)	5/18 8/18 11/18	3.1	2.1 – 4.0	
Chlorodibromoacetic Acid (ppb)	5/18 8/18 11/18	0.1	ND - 0.3	
Tribromoacetic Acid (ppb)	5/18 8/18 11/18	ND	N/A	

Total Haloacetic Acids (ppb)	5/18 8/18 11/18	44	34 - 49
Total Haloacetic Acids UCMR4 (ppb)	5/18 8/18 11/18	50	39 - 56
Total Haloacetic Acids – Br (ppb)	5/18 8/18 11/18	6.7	4.7 – 8.5

(B02) North 321 Fire Dept.

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
Monochloroacetic Acid (ppb)	2/19	ND	N/A	
Monobromoacetic Acid (ppb)	2/19	ND	N/A	
Dichloroacetic Acid (ppb)	2/19	8.7	8.7	
Trichloroacetic Acid (ppb)	2/19	8.7	8.7	
Bromochloroacetic Acid (ppb)	2/19	2.1	2.1	
Dibromoacetic Acid (ppb)	2/19	ND	N/A	
Bromodichloroacetic Acid (ppb)	2/19	1.8	1.8	
Chlorodibromoacetic Acid (ppb)	2/19	ND	N/A	
Tribromoacetic Acid (ppb)	2/19	ND	N/A	
Total Haloacetic Acids (ppb)	2/19	17	17	
Total Haloacetic Acids UCMR4 (ppb)	2/19	21	21	
Total Haloacetic Acids – Br (ppb)	2/19	3.9	3.9	

(B03) North Brook Elementary

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
Monochloroacetic Acid (ppb)	5/18 8/18 11/18	1.36	ND – 4.1	
Monobromoacetic Acid (ppb)	5/18 8/18 11/18	0.11	ND – 0.32	
Dichloroacetic Acid (ppb)	5/18 8/18 11/18	21.7	21 - 22	
Trichloroacetic Acid (ppb)	5/18 8/18 11/18	22	22 - 23	
Bromochloroacetic Acid (ppb)	5/18 8/18 11/18	4.7	3.1 – 6.3	
Dibromoacetic Acid (ppb)	5/18 8/18 11/18	.37	ND – 0.63	
Bromodichloroacetic Acid (ppb)	5/18 8/18 11/18	4.2	2.9 – 5.4	
Chlorodibromoacetic Acid (ppb)	5/18 8/18 11/18	.36	ND - .61	
Tribromoacetic Acid (ppb)	5/18 8/18 11/18	ND	N/A	

Total Haloacetic Acids (ppb)	5/18 8/18 11/18	46	44 - 48
Total Haloacetic Acids UCMR4 (ppb)	5/18 8/18 11/18	55	49 - 58
Total Haloacetic Acids – Br (ppb)	5/18 8/18 11/18	9.8	6.3 - 13

B03) North Brook Elementary

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
Monochloroacetic Acid (ppb)	2/19	ND	N/A	
Monobromoacetic Acid (ppb)	2/19	ND	N/A	
Dichloroacetic Acid (ppb)	2/19	14	14	
Trichloroacetic Acid (ppb)	2/19	16	16	
Bromochloroacetic Acid (ppb)	2/19	2.2	2.2	
Dibromoacetic Acid (ppb)	2/19	ND	N/A	
Bromodichloroacetic Acid (ppb)	2/19	2.1	2.1	
Chlorodibromoacetic Acid (ppb)	2/19	ND	N/A	
Tribromoacetic Acid (ppb)	2/19	ND	N/A	
Total Haloacetic Acids (ppb)	2/19	30	30	
Total Haloacetic Acids UCMR4 (ppb)	2/19	34	34	
Total Haloacetic Acids – Br (ppb)	2/19	4.3	4.3	

(B04) Verdict Ridge Golf Course

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
Monochloroacetic Acid (ppb)	5/18 8/18 11/18	1.23	ND – 3.7	
Monobromoacetic Acid (ppb)	5/18 8/18 11/18	ND	N/A	
Dichloroacetic Acid (ppb)	5/18 8/18 11/18	18	18 - 18	
Trichloroacetic Acid (ppb)	5/18 8/18 11/18	20	19 - 21	
Bromochloroacetic Acid (ppb)	5/18 8/18 11/18	4.5	2.5 – 6.0	
Dibromoacetic Acid (ppb)	5/18 8/18 11/18	0.40	ND – 0.65	
Bromodichloroacetic Acid (ppb)	5/18 8/18 11/18	4	2.4 – 5.3	
Chlorodibromoacetic Acid (ppb)	5/18 8/18 11/18	0.39	ND – 0.65	

Tribromoacetic Acid (ppb)	5/18 8/18 11/18	ND	N/A
Total Haloacetic Acids (ppb)	5/18 8/18 11/18	40	39 - 41
Total Haloacetic Acids UCMR4 (ppb)	5/18 8/18 11/18	49	44 - 52
Total Haloacetic Acids – Br (ppb)	5/18 8/18 11/18	9.6	4.9 - 13

(B04) Verdict Ridge Golf Course

Contaminant (units)	Sample Date	Your Water (average)	Range
			Low High
Monochloroacetic Acid (ppb)	2/19	ND	N/A
Monobromoacetic Acid (ppb)	2/19	ND	N/A
Dichloroacetic Acid (ppb)	2/19	12	12
Trichloroacetic Acid (ppb)	2/19	14	14
Bromochloroacetic Acid (ppb)	2/19	1.9	1.9
Dibromoacetic Acid (ppb)	2/19	ND	N/A
Bromodichloroacetic Acid (ppb)	2/19	1.9	1.9
Chlorodibromoacetic Acid (ppb)	2/19	ND	N/A
Tribromoacetic Acid (ppb)	2/19	ND	N/A
Total Haloacetic Acids (ppb)	2/19	27	27
Total Haloacetic Acids UCMR4 (ppb)	2/19	30	30
Total Haloacetic Acids – Br (ppb)	2/19	3.8	3.8

Inorganic Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range	MCLG	MCL	Likely Source of Contamination
				Low High			
Fluoride (ppm)	2/4/19	N	0	N/A	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

The PWS Section requires monitoring for other misc. contaminants, some for which the EPA has set national secondary drinking water standards (SMCLs) because they may cause cosmetic effects or aesthetic effects (such as taste, odor, and/or color) in drinking water. The contaminants with SMCLs normally do not have any health effects and normally do not affect the safety of your water.

Other Miscellaneous Water Characteristics Contaminants

Contaminant (units)	Sample Date	Your Water	Range	SMCL
			Low High	
Iron (ppm)	2/4/19	N/D	N/A	0.3 mg/L
Manganese (ppm)	2/4/19	N/D	N/A	0.05 mg/L
Nickel (ppm)	2/4/19	N/D	N/A	N/A
Sodium (ppm)	2/4/19	11	N/A	N/A

Sulfate (ppm)	2/4/19	23.4	N/A	250 mg/L
pH	2/4/19	7.07	N/A	6.5 to 8.5

Cryptosporidium / Giardia

To comply with the Long Term 2 Enhanced Surface Water Treatment (LT2) Rule, the Lincoln County WTP has been monthly monitoring for Cryptosporidium and Giardia in the source water (Lake Norman).

During testing all samples for Cryptosporidium (oocysts/L) were found at not detected levels.

Cryptosporidium is a microbial pathogen found in surface water throughout the U.S. Although filtration removes Cryptosporidium, the most commonly-used filtration methods cannot guarantee 100 percent removal. Ingestion of Cryptosporidium may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people, infants and small children, and the elderly are at greater risk of developing life-threatening illness. We encourage immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection. Cryptosporidium must be ingested to cause disease, and it may be spread through means other than drinking water.

Giarda	Sample Date
0.1 (cysts/L)	2/18
0.1 (cysts/L)	4/18

For information on Giardia, the USEPA factsheet may be viewed on the Web at:
<https://www.epa.gov/sites/production/files/2015-10/documents/giardia-factsheet.pdf>